



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-5146BQ0294

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Distributor <i>Vertreiber</i>	KEMIS Plus d.o.o. Preserje Kajuhova 4, SLO-1235 Radomlje
Product Category <i>Produktart</i>	greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146)
Product Description <i>Produktbezeichnung</i>	sealing material for metallic screwed joints in gas appliances, gas equipments and water heating equipments, not allowed in the gas installation according to DVGW-TRGI 2018
Model <i>Modell</i>	KEMISKOL T 138
Test Reports <i>Prüfberichte</i>	type testing: 20-00213 from 20.07.2020 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 751-1 (01.05.1997)

Date of Expiry / File No. 03.08.2025 / 20-0491-GNU
Ablaufdatum / Aktenzeichen

12.08.2020 Kö B-1/2 *i.A.*

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
KEMISKOL T 138	class: H	for diameters > DN 10 up to DN 50

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

approved for use in coarse metallic threads

not allowed in the gas installation according to DVGW-TRGI 2018

